

NOTES:

1. TRANSVERSE SAWED CONTRACTION
JOINTS AT 12' INTERVALS FOR
CONCRETE PAVEMENT.

\*\* 2. LIME SHALL BE APPLIED AT 6% BY
WEIGHT MINIMUM QUANTITY IS 36 LBS/SY.
IN SOME AREAS A GREATER QUANTITY
(OR A LIME SERIES TEST) MAY BE
REQUIRED AT THE CITY'S DISCRETION.

\*\* 3. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 36#/SY.

28' CONCRETE PAVEMENT SECTION TYPICAL CROSS SECTION

NTS

REVISIONS Rev	ised 11/16/99 (Bar Siz	e & Concrete Layer)
CITY OF ARLINGTON, TEXAS		
PROJECT NUMBER		
PROJECT NAME		
( PROJECT LIMITS )		
DATE:	SCALE:	SHEET07
DESIGNOO BY:	DRAWN BY:	CHIRCKIED BY: